Pre-bid Meeting

Truchas Fire Department Underground Water Storage Project

IFB 2022-06

Q&A

May 3, 2022 10 am

- 1. How many inlets and outlets are needed? Do you know locations and sizes?
 - a. There needs to be an outlet for the pump and on the tank. With 2 ½ fields at the top of the tank.
- 2. Should the two pumps be in line with each other and how much output should they have?
 - a. They should 500 GPM or higher and they be sequential.
- 3. Are these storage tanks for fire protection or for potable usage as well?
 - a. These will be used for fire suppression only.
- 4. Does a NMFPA 32 need to be obtained?
 - a. No
- 5. Does the metal have to be domestic or AIF certified?
 - a. No
- 6. What kind of paint needs to be used?
 - a. Fibergloss to prevent rusting
- 7. Can the tank be steel welded?
 - a. Yes, we are open to that idea.
- 8. Is this a design build or does it have plans?
 - a. No drawings or plans.